

FIRE STOPPING

BY NORSEAL

SILVERSEAL

FSI



Application

Rigid floor constructions penetrated by various cables and metallic pipes

Fixing

Easy mix compound

Performance

Fire tested to BS 476:20 & EN 1366-3
Classified in accordance with EN 13501-2
CE Marked ETA 20-1144
UL EU Accreditation UL-EU-01025-CPR
UAE Certificate of Compliance
Airborne Sound tested to EN 10140-2
Air Permeability tested to EN 1026

Material

Gypsum based mortar

Colour

Grey

Size

20KG bag

Expected Shelf Life

6 months

Order code

Please contact the Norseal office on 01661 520930

 5 Regents Drive
Prudhoe
Northumberland
NE42 6PX

 norseal.co.uk

 firestopping@norseal.co.uk

 01661 520 930

Registered at Companies House Cardiff No. 04317595 VAT Reg. No. 733 9466 08